


LUMINAIRE PHOTOMETRIC TEST REPORT


Test:U:23.985V I:0.3996A P:9.5852W PF:1.0000 Freq:0Hz Lamp Flux:534.812x1 lm		
NAME: 016015	TYPE:016015	WEIGHT:
SPEC.:1000*16*15	DIM.: 1000*16*15	SERIAL No.:
MFR.: BLUEVISION	SUR.:1000*16	Shielding Angle:

DATA OF LAMP		PHOTOMETRIC DATA Eff: 55.80 lm/W			
MODEL	016015	I _{max} (cd)	184.0	S/MH(C0/180)	1.26
NOMINAL POWER(W)	9.585	LOR(%)	100.0	S/MH(C90/270)	1.26
RATED VOLTAGE(V)	24	TOTAL FLUX(lm)	534.81	η UP,DN(C0-180)	0.6,49.7
NOMINAL FLUX(lm)	534.812	CIE CLASS	DIRECT	η UP,DN(C180-360)	0.6,49.1
LAMPS INSIDE	1	η up(%)	1.2	CIBSE SHR NOM	1.25
TEST VOLTAGE(V)	24	η down(%)	98.8	CIBSE SHR MAX	1.35

LUMINOUS INTENSITY DISTRIBUTION DIAGRAM



C0 PLANE ISOLUX DIAGRAM (UNIT:lx)



C Range: 0 - 360DEG
 C Interval: 45.0DEG
 Test Speed: HIGH
 Temperature:25.3DEG
 Operators:KEVINLI
 Test Date:2020-08-13

γ Range: 0 - 180DEG
 γ Interval: 1.0DEG
 Test System:EVERFINE GO-2000A_V1 SYSTEM V2.00.412
 Humidity:65.0%
 Test Distance:9.650m [K=1.0000]
 Remarks: S2835L120Q24WW30K8IP67-12-N-016015

ZONAL FLUX DIAGRAM

ZONAL FLUX DIAGRAM:


γ	C0	C45	C90	C135	C180	C225	C270	C315	γ	Φ zone	Φ total	%lum, lamp
10	180.8	181.1	180.9	180.7	180.8	180.6	180.7	180.9	0- 10	17.41	17.41	3.26,3.26
20	171.4	171.9	171.5	171.3	171.3	171.0	171.4	171.5	10- 20	49.92	67.33	12.6,12.6
30	156.3	157.0	156.5	156.2	156.2	155.7	156.2	156.5	20- 30	75.85	143.2	26.8,26.8
40	136.2	136.9	136.2	135.9	136.1	135.2	135.9	136.3	30- 40	91.83	235.0	43.9,43.9
50	111.8	112.3	111.5	111.2	111.7	110.6	110.5	111.7	40- 50	95.83	330.8	61.9,61.9
60	83.45	84.00	82.85	82.83	83.44	82.15	76.90	83.40	50- 60	86.97	417.8	78.1,78.1
70	52.40	52.84	47.27	51.65	52.55	50.96	40.76	52.15	60- 70	65.77	483.6	90.4,90.4
80	22.10	21.82	11.28	20.87	22.21	20.39	8.453	21.32	70- 80	35.71	519.3	97.1,97.1
90	3.952	2.830	0.0958	2.413	3.688	2.398	0.0510	2.738	80- 90	9.103	528.4	98.8,98.8
100	1.518	1.039	0.1589	0.8999	1.184	1.020	0.1974	1.072	90-100	1.339	529.7	99,99
110	1.285	0.9500	0.3053	0.9063	1.096	0.9376	0.3563	0.9064	100-110	0.9044	530.6	99.2,99.2
120	1.222	0.7919	0.4961	0.9893	1.127	0.9250	0.5347	0.7722	110-120	0.8340	531.5	99.4,99.4
130	1.222	0.9000	0.6996	1.072	1.153	0.9439	0.7380	0.8104	120-130	0.8030	532.3	99.5,99.5
140	1.291	1.058	0.9161	1.188	1.272	1.071	0.9418	0.9573	130-140	0.7819	533.0	99.7,99.7
150	1.329	1.172	1.075	1.238	1.285	1.109	1.120	1.085	140-150	0.7114	533.8	99.8,99.8
160	1.329	1.299	1.196	1.296	1.297	1.197	1.253	1.193	150-160	0.5635	534.3	99.9,99.9
170	1.316	1.368	1.298	1.366	1.367	1.299	1.355	1.276	160-170	0.3657	534.7	100,100
180	1.354	1.375	1.342	1.366	1.379	1.356	1.361	1.347	170-180	0.1282	534.8	100,100
DEG	LUMINOUS INTENSITY:cd									UNIT:lm		

C Range: 0 - 360DEG
C Interval: 45.0DEG
Test Speed: HIGH
Temperature:25.3DEG
Operators:KEVINLI
Test Date:2020-08-13

γ Range: 0 - 180DEG
 γ Interval: 1.0DEG
Test System:EVERFINE GO-2000A_V1 SYSTEM V2.00.412
Humidity:65.0%
Test Distance:9.650m [K=1.0000]
Remarks: S2835L120Q24WW30K8IP67-12-N-016015

LUMINANCE LIMITATION CURVES

Test:U:23.985V I:0.3996A P:9.5852W PF:1.0000 Freq:0Hz Lamp Flux:534.812x1 lm		
NAME: 016015	TYPE:016015	WEIGHT:
SPEC.:1000*16*15	DIM.: 1000*16*15	SERIAL No.:
MFR.: BLUEVISION	SUR.:1000*16	Shielding Angle:



LUMINANCE cd/(m2)		
G (DEG)	C0/180	C90/270
85	7555	187
80	8012	4050
75	8933	6785
70	9645	8614
65	10153	9818
60	10506	10328
55	10765	10608
50	10950	10811
45	11087	10955


C Range: 0 - 360DEG
C Interval: 45.0DEG
Test Speed: HIGH
Temperature:25.3DEG
Operators:KEVINLI
Test Date:2020-08-13

γ Range: 0 - 180DEG
γ Interval: 1.0DEG
Test System:EVERFINE GO-2000A_V1 SYSTEM V2.00.412
Humidity:65.0%
Test Distance:9.650m [K=1.0000]
Remarks: S2835L120Q24WW30K8IP67-12-N-016015

CU AND LUMINAIRE BUDGETARY ESTIMATE DIAGRAM

Test:U:23.985V I:0.3996A P:9.5852W PF:1.0000 Freq:0Hz Lamp Flux:534.812x1 lm		
NAME: 016015	TYPE:016015	WEIGHT:
SPEC.:1000*16*15	DIM.: 1000*16*15	SERIAL No.:
MFR.: BLUEVISION	SUR.:1000*16	Shielding Angle:

ρ_{cc}	80%			70%			50%			30%			10%			0
ρ_w	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	0
ρ_{fc}	20%			20%			20%			20%			20%			0
RCR	RCR:Room Cavity Ratio						Coefficients of Utilization(CU)									
0.0	1.19	1.19	1.19	1.16	1.16	1.16	1.10	1.10	1.10	1.05	1.05	1.05	1.01	1.01	1.01	.99
1.0	1.04	.99	.96	1.01	.97	.94	.97	.94	.91	.93	.90	.88	.89	.87	.85	.83
2.0	.90	.84	.78	.88	.82	.77	.85	.79	.75	.81	.77	.73	.78	.74	.71	.69
3.0	.79	.71	.65	.78	.70	.64	.74	.68	.63	.71	.66	.61	.69	.64	.60	.58
4.0	.70	.61	.55	.69	.60	.54	.66	.59	.53	.64	.57	.52	.61	.56	.52	.49
5.0	.63	.54	.47	.61	.53	.47	.59	.52	.46	.57	.50	.45	.55	.49	.45	.43
6.0	.56	.47	.41	.55	.47	.41	.53	.46	.40	.52	.45	.40	.50	.44	.39	.37
7.0	.51	.42	.36	.50	.42	.36	.48	.41	.35	.47	.40	.35	.45	.39	.35	.33
8.0	.47	.38	.32	.46	.38	.32	.44	.37	.32	.43	.36	.31	.42	.36	.31	.29
9.0	.43	.34	.29	.42	.34	.29	.41	.34	.29	.40	.33	.28	.38	.32	.28	.26
10.0	.39	.31	.26	.39	.31	.26	.38	.31	.26	.37	.30	.26	.36	.30	.25	.24



C Range: 0 - 360DEG
 C Interval: 45.0DEG
 Test Speed: HIGH
 Temperature:25.3DEG
 Operators:KEVINLI
 Test Date:2020-08-13

γ Range: 0 - 180DEG
 γ Interval: 1.0DEG
 Test System:EVERFINE GO-2000A_V1 SYSTEM V2.00.412
 Humidity:65.0%
 Test Distance:9.650m [K=1.0000]
 Remarks: S2835L120Q24WW30K8IP67-12-N-016015

WEC AND CCEC

Test:U:23.985V I:0.3996A P:9.5852W PF:1.0000 Freq:0Hz Lamp Flux:534.812x1 lm		
NAME: 016015	TYPE:016015	WEIGHT:
SPEC.:1000*16*15	DIM.: 1000*16*15	SERIAL No.:
MFR.: BLUEVISION	SUR.:1000*16	Shielding Angle:

pcc	80%			70%			50%			30%			10%			0	
pw	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	0	
pfc	20%			20%			20%			20%			20%			0	
RCR	RCR:Room Cavity Ratio						Wall Exitance Coefficients (WEC)										
0.0																	
1.0	.307	.175	.055	.300	.171	.054	.286	.164	.052	.273	.157	.050	.261	.151	.049		
2.0	.290	.159	.049	.283	.156	.048	.271	.151	.047	.260	.146	.046	.249	.141	.044		
3.0	.269	.143	.043	.263	.141	.042	.252	.137	.042	.242	.133	.041	.233	.129	.040		
4.0	.248	.129	.038	.243	.127	.038	.234	.124	.037	.225	.121	.036	.216	.117	.036		
5.0	.230	.117	.034	.225	.116	.034	.217	.113	.033	.209	.110	.033	.201	.107	.032		
6.0	.213	.107	.031	.209	.106	.030	.201	.103	.030	.194	.101	.030	.187	.099	.029		
7.0	.199	.098	.028	.195	.097	.028	.188	.095	.027	.181	.093	.027	.175	.091	.027		
8.0	.185	.091	.025	.182	.090	.025	.176	.088	.025	.170	.086	.025	.165	.085	.025		
9.0	.174	.084	.023	.171	.083	.023	.165	.082	.023	.160	.080	.023	.155	.079	.023		
10.0	.163	.078	.022	.161	.078	.022	.156	.076	.021	.151	.075	.021	.146	.074	.021		

pcc	80%			70%			50%			30%			10%			0
pw	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	0
pfc	20%			20%			20%			20%			20%			0
RCR	RCR:Room Cavity Ratio						Ceiling Cavity Exitance Coefficients(CCEC)									
0.0	.200	.200	.200	.171	.171	.171	.116	.116	.116	.067	.067	.067	.021	.021	.021	
1.0	.189	.165	.144	.162	.142	.124	.111	.098	.086	.064	.057	.050	.020	.018	.016	
2.0	.181	.141	.108	.155	.122	.093	.106	.084	.065	.061	.049	.038	.020	.016	.012	
3.0	.174	.124	.084	.149	.107	.073	.102	.074	.051	.059	.043	.030	.019	.014	.010	
4.0	.166	.110	.068	.142	.095	.059	.098	.066	.041	.057	.039	.025	.018	.013	.008	
5.0	.159	.100	.057	.136	.087	.049	.094	.060	.035	.054	.035	.021	.018	.012	.007	
6.0	.152	.092	.049	.130	.079	.042	.090	.056	.030	.052	.033	.018	.017	.011	.006	
7.0	.145	.085	.043	.125	.073	.037	.086	.052	.026	.050	.030	.016	.016	.010	.005	
8.0	.138	.079	.038	.119	.069	.033	.082	.048	.024	.048	.028	.014	.016	.009	.005	
9.0	.132	.074	.035	.114	.064	.030	.079	.045	.022	.046	.027	.013	.015	.009	.004	
10.0	.127	.070	.032	.109	.061	.028	.076	.043	.020	.044	.025	.012	.014	.008	.004	

C Range: 0 - 360DEG
C Interval: 45.0DEG
Test Speed: HIGH
Temperature:25.3DEG
Operators:KEVINLI
Test Date:2020-08-13

γ Range: 0 - 180DEG
γ Interval: 1.0DEG
Test System:EVERFINE GO-2000A_V1 SYSTEM V2.00.412
Humidity:65.0%
Test Distance:9.650m [K=1.0000]
Remarks: S2835L120Q24WW30K8IP67-12-N-016015

UGR(Unified Glare Rating) Table

Test:U:23.985V I:0.3996A P:9.5852W PF:1.0000 Freq:0Hz Lamp Flux:534.812x1 lm										
NAME: 016015					TYPE:016015			WEIGHT:		
SPEC.:1000*16*15					DIM.: 1000*16*15			SERIAL No.:		
MFR.: BLUEVISION					SUR.:1000*16			Shielding Angle:		
ceiling/cavity	0.7	0.7	0.5	0.5	0.3	0.7	0.7	0.5	0.5	0.3
walls	0.5	0.3	0.5	0.3	0.3	0.5	0.3	0.5	0.3	0.3
working plane	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
Room dimensions	Viewed crosswise					Viewed endwise				
x = 2H y = 2H	23.3	24.8	23.6	25.1	25.3	23.3	24.8	23.6	25.0	25.2
3H	24.9	26.3	25.2	26.5	26.8	24.7	26.1	25.0	26.3	26.6
4H	25.5	26.8	25.8	27.1	27.4	25.1	26.4	25.5	26.7	27.0
6H	25.9	27.2	26.3	27.5	27.8	25.3	26.5	25.6	26.8	27.1
8H	26.1	27.3	26.4	27.6	27.9	25.3	26.5	25.6	26.8	27.1
12H	26.2	27.3	26.5	27.6	28.0	25.2	26.4	25.6	26.7	27.0
4H 2H	24.0	25.3	24.3	25.6	25.8	23.9	25.2	24.2	25.5	25.8
3H	25.7	26.8	26.1	27.2	27.5	25.5	26.7	25.9	27.0	27.3
4H	26.4	27.5	26.8	27.8	28.2	26.1	27.1	26.4	27.5	27.8
6H	27.0	27.9	27.4	28.3	28.7	26.3	27.3	26.7	27.6	28.0
8H	27.2	28.0	27.6	28.4	28.8	26.3	27.2	26.8	27.6	28.0
12H	27.3	28.1	27.8	28.5	29.0	26.3	27.1	26.8	27.5	27.9
8H 4H	26.7	27.5	27.1	27.9	28.3	26.3	27.2	26.8	27.6	28.0
6H	27.4	28.1	27.8	28.5	29.0	26.7	27.5	27.2	27.9	28.3
8H	27.7	28.3	28.1	28.7	29.2	26.8	27.5	27.3	27.9	28.4
12H	27.9	28.4	28.4	28.9	29.4	26.8	27.4	27.3	27.8	28.3
12H 4H	26.7	27.5	27.1	27.9	28.3	26.4	27.2	26.8	27.6	28.0
6H	27.4	28.1	27.9	28.5	29.0	26.8	27.5	27.3	27.9	28.4
8H	27.7	28.3	28.2	28.8	29.3	26.9	27.5	27.4	27.9	28.4
Variations with the observer position at spacings:										
S = 1.0H	+ 0.1 / - 0.2					+ 0.2 / - 0.2				
1.5H	+ 0.2 / - 0.3					+ 0.2 / - 0.4				
2.0H	+ 0.2 / - 0.3					+ 0.2 / - 0.4				

CIE Pub.117, 534.8 lm Total Lamp Luminous Flux Correct (8log(F/F0) = -2.2)
Area: 0.016 m2

C Range: 0 - 360DEG
C Interval: 45.0DEG
Test Speed: HIGH
Temperature:25.3DEG
Operators:KEVINLI
Test Date:2020-08-13

γ Range: 0 - 180DEG
 γ Interval: 1.0DEG
Test System:EVERFINE GO-2000A_V1 SYSTEM V2.00.412
Humidity:65.0%
Test Distance:9.650m [K=1.0000]
Remarks: S2835L120Q24WW30K8IP67-12-N-016015

UTILIZATION FACTORS TABLE

Test:U:23.985V I:0.3996A P:9.5852W PF:1.0000 Freq:0Hz Lamp Flux:534.812x1 lm		
NAME: 016015	TYPE:016015	WEIGHT:
SPEC.:1000*16*15	DIM.: 1000*16*15	SERIAL No.:
MFR.: BLUEVISION	SUR.:1000*16	Shielding Angle:


REFLECTANCE										
Ceiling	0.8	0.8	0.8	0.7	0.7	0.7	0.5	0.5	0.5	0
Walls	0.7	0.5	0.3	0.7	0.5	0.3	0.7	0.5	0.3	0
Working plane	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0
ROOM INDEX	UTILIZATION FACTORS (PERCENT) $k(RI) \times RCR = 5$									
$k = 0.60$	57	45	38	56	45	38	55	45	38	32
0.80	67	55	48	66	55	48	64	54	47	40
1.00	76	64	57	74	64	57	72	65	56	49
1.25	83	72	65	81	71	65	78	70	64	56
1.50	88	78	71	86	77	70	83	75	69	61
2.00	95	86	80	93	85	79	89	82	77	69
2.50	99	91	85	96	89	84	92	87	82	73
3.00	102	95	90	100	93	88	95	90	86	77
4.00	106	100	96	103	98	94	99	95	91	82
5.00	108	104	99	106	102	98	101	98	95	85
ROOM INDEX	UF (total)									Direct
According to DIN EN 13032-2 2004			Suspended					SHRNM = 1.25		

C Range: 0 - 360DEG
C Interval: 45.0DEG
Test Speed: HIGH
Temperature:25.3DEG
Operators:KEVINLI
Test Date:2020-08-13

γ Range: 0 - 180DEG
 γ Interval: 1.0DEG
Test System:EVERFINE GO-2000A_V1 SYSTEM V2.00.412
Humidity:65.0%
Test Distance:9.650m [K=1.0000]
Remarks: S2835L120Q24WW30K8IP67-12-N-016015

ISOCANDELA DIAGRAM

Test:U:23.985V I:0.3996A P:9.5852W PF:1.0000 Freq:0Hz Lamp Flux:534.812x1 lm		
NAME: 016015	TYPE:016015	WEIGHT:
SPEC.:1000*16*15	DIM.: 1000*16*15	SERIAL No.:
MFR.: BLUEVISION	SUR.:1000*16	Shielding Angle:




C Range: 0 - 360DEG
C Interval: 45.0DEG
Test Speed: HIGH
Temperature:25.3DEG
Operators:KEVINLI
Test Date:2020-08-13

γ Range: 0 - 180DEG
 γ Interval: 1.0DEG
Test System:EVERFINE GO-2000A_V1 SYSTEM V2.00.412
Humidity:65.0%
Test Distance:9.650m [K=1.0000]
Remarks: S2835L120Q24WW30K8IP67-12-N-016015

AAI Figure

Test:U:23.985V I:0.3996A P:9.5852W PF:1.0000 Freq:0Hz Lamp Flux:534.812x1 lm		
NAME: 016015	TYPE:016015	WEIGHT:
SPEC.:1000*16*15	DIM.: 1000*16*15	SERIAL No.:
MFR.: BLUEVISION	SUR.:1000*16	Shielding Angle:




Note:The Curves indicate the illuminated area and the average illumination when the luminaire is at different distance.

C Range: 0 - 360DEG
C Interval: 45.0DEG
Test Speed: HIGH
Temperature:25.3DEG
Operators:KEVINLI
Test Date:2020-08-13

γ Range: 0 - 180DEG
γ Interval: 1.0DEG
Test System:EVERFINE GO-2000A_V1 SYSTEM V2.00.412
Humidity:65.0%
Test Distance:9.650m [K=1.0000]
Remarks: S2835L120Q24WW30K8IP67-12-N-016015

ISOLUX DIAGRAM

Test:U:23.985V I:0.3996A P:9.5852W PF:1.0000 Freq:0Hz Lamp Flux:534.812x1 lm		
NAME: 016015	TYPE:016015	WEIGHT:
SPEC.:1000*16*15	DIM.: 1000*16*15	SERIAL No.:
MFR.: BLUEVISION	SUR.:1000*16	Shielding Angle:



C Range: 0 - 360DEG
C Interval: 45.0DEG
Test Speed: HIGH
Temperature:25.3DEG
Operators:KEVINLI
Test Date:2020-08-13

γ Range: 0 - 180DEG
γ Interval: 1.0DEG
Test System:EVERFINE GO-2000A_V1 SYSTEM V2.00.412
Humidity:65.0%
Test Distance:9.650m [K=1.0000]
Remarks: S2835L120Q24WW30K8IP67-12-N-016015

LED Avg.L Report

Test:U:23.985V I:0.3996A P:9.5852W PF:1.0000 Freq:0Hz Lamp Flux:534.812x1 lm		
NAME: 016015	TYPE:016015	WEIGHT:
SPEC.:1000*16*15	DIM.: 1000*16*15	SERIAL No.:
MFR.: BLUEVISION	SUR.:1000*16	Shielding Angle:


AvgL	cd/m2
L_0~180 (65) av	10084
L_0~180 (75) av	8888
L_0~180 (85) av	7512
L_90~270 (65) av	9274
L_90~270 (75) av	6210
L_90~270 (85) av	108
L_45 (65) av	10021
L_45 (75) av	8704
L_45 (85) av	6465

Standard: GB/T 29293-2012

C Range: 0 - 360DEG
 C Interval: 45.0DEG
 Test Speed: HIGH
 Temperature:25.3DEG
 Operators:KEVINLI
 Test Date:2020-08-13

γ Range: 0 - 180DEG
 γ Interval: 1.0DEG
 Test System:EVERFINE GO-2000A_V1 SYSTEM V2.00.412
 Humidity:65.0%
 Test Distance:9.650m [K=1.0000]
 Remarks: S2835L120Q24WW30K8IP67-12-N-016015

Planar Illuminance Curve



C Range: 0 - 360DEG
C Interval: 45.0DEG
Test Speed: HIGH
Temperature: 25.3DEG
Operators: KEVINLI
Test Date: 2020-08-13

γ Range: 0 - 180DEG
 γ Interval: 1.0DEG
Test System: EVERFINE GO-2000A_V1 SYSTEM V2.00.412
Humidity: 65.0%
Test Distance: 9.650m [K=1.0000]
Remarks: S2835L120Q24WW30K8IP67-12-N-016015

LUMINOUS DISTRIBUTION INTENSITY DATA

Test:U:23.985V I:0.3996A P:9.5852W PF:1.0000 Freq:0Hz Lamp Flux:534.812x1 lm		
NAME: 016015	TYPE:016015	WEIGHT:
SPEC.:1000*16*15	DIM.: 1000*16*15	SERIAL No.:
MFR.: BLUEVISION	SUR.:1000*16	Shielding Angle:

Table--1

UNIT: cd

C (DEG) γ (DEG)	0	45	90	135	180	225	270	315										
0	184	184	184	184	184	184	184	184										
5	183	183	183	183	183	183	183	183										
10	181	181	181	181	181	181	181	181										
15	177	177	177	177	177	177	177	177										
20	171	172	172	171	171	171	171	172										
25	165	165	165	164	164	164	165	165										
30	156	157	157	156	156	156	156	157										
35	147	148	147	147	147	146	147	147										
40	136	137	136	136	136	135	136	136										
45	125	125	124	124	125	123	124	125										
50	112	112	111	111	112	111	111	112										
55	98.1	98.6	97.6	97.5	98.0	96.9	94.5	98.0										
60	83.4	84.0	82.9	82.8	83.4	82.2	76.9	83.4										
65	68.2	68.7	66.6	67.5	68.2	66.8	58.8	68.0										
70	52.4	52.8	47.3	51.7	52.6	51.0	40.8	52.2										
75	36.7	36.9	28.2	35.8	36.9	35.1	23.3	36.3										
80	22.1	21.8	11.3	20.9	22.2	20.4	8.45	21.3										
85	10.5	9.56	0.26	8.85	10.5	8.53	0.04	9.13										
90	3.95	2.83	0.10	2.41	3.69	2.40	0.05	2.74										
95	1.93	1.25	0.09	1.02	1.55	1.20	0.10	1.31										
100	1.52	1.04	0.16	0.90	1.18	1.02	0.20	1.07										
105	1.36	0.99	0.23	0.90	1.09	0.97	0.27	0.98										
110	1.29	0.95	0.31	0.91	1.10	0.94	0.36	0.91										
115	1.25	0.79	0.39	0.94	1.11	0.92	0.45	0.80										
120	1.22	0.79	0.50	0.99	1.13	0.92	0.53	0.77										
125	1.22	0.85	0.60	1.03	1.13	0.92	0.63	0.77										
130	1.22	0.90	0.70	1.07	1.15	0.94	0.74	0.81										
135	1.22	0.98	0.80	1.14	1.21	1.00	0.83	0.87										
140	1.29	1.06	0.92	1.19	1.27	1.07	0.94	0.96										
145	1.32	1.11	0.99	1.23	1.28	1.10	1.03	1.03										
150	1.33	1.17	1.07	1.24	1.28	1.11	1.12	1.08										
155	1.33	1.27	1.14	1.26	1.28	1.17	1.20	1.17										
160	1.33	1.30	1.20	1.30	1.30	1.20	1.25	1.19										
165	1.32	1.32	1.26	1.33	1.32	1.26	1.30	1.24										
170	1.32	1.37	1.30	1.37	1.37	1.30	1.36	1.28										
175	1.34	1.37	1.32	1.37	1.37	1.33	1.36	1.32										
180	1.35	1.37	1.34	1.37	1.38	1.36	1.36	1.35										

C Range: 0 - 360DEG
C Interval: 45.0DEG
Test Speed: HIGH
Temperature:25.3DEG
Operators:KEVINLI
Test Date:2020-08-13

γ Range: 0 - 180DEG
γ Interval: 1.0DEG
Test System:EVERFINE GO-2000A_V1 SYSTEM V2.00.412
Humidity:65.0%
Test Distance:9.650m [K=1.0000]
Remarks: S2835L120Q24WW30K8IP67-12-N-016015